

# JAIPUR DEVELOPMENT AUTHORITY

Office of Information Technology

JDA/IT(1074516)/UPS/2015

Dated : 09/10/2015


## Minutes of Pre-Bid Meeting

NIB No. : JDA-IT-09:2015-16 eProc Tender ID: 2015\_JDAJP\_24874\_1

The Pre-Bid meeting for "Supply of Uninterrupted Power Supply (UPS) and Buyback of Batteries" was held on 08/10/2015 at 11:00 AM. Only one bidder M/S Novateur Electrical & Digital Systems Pvt Ltd., submitted the queries within scheduled date and time. In response to the pre-bid queries the committee accepted the suggestions as mentioned below:

#	NIB Page No.	Section	Details as per NIB Document	Amended as
(1)	(2)	(3)	(4)	(5)
1	11	3 (1.A.III)	The UPS Should is to be supplied duly inspected from RITES / MNIT. The inspection Charges shall be borne by the bidder.	The UPS is to be supplied duly inspected from any Government Certified Lab as mutually agreed after award of Work. The inspection Charges shall be borne by the bidder.
2	42	Annexure-2 Output (7-Parallel Facilities)	Up to 4 Units Minimum	Up to 3 Units Minimum
3	42	Annexure-2 Output (10-Overall Efficiency)	> 93%	> 90%
4	43	Annexure-2 Output (10-Overall Efficiency)	> 92%	> 90%
5	42	Annexure-2 Output (12-STANDARD)	ROHS	Deleted
6	43	Annexure-2 Output (12-STANDARD )	ROHS	Deleted
7	42	Annexure-2 DC CHARACTERISTICS (1- Nominal DC bus voltage )	Should be variable 276/288/300 – Batteries Qty 23/24/25	Should be variable 276/288 – Batteries Qty 23/24
8	42	Annexure-2 DC CHARACTERISTICS (2- AH capacity of SMF batteries (Exide / Amara Raja / Panasonic)	150 AH X 25 Nos	150 AH X 24 Nos
9	43	Annexure-2 DC CHARACTERISTICS (1- Nominal DC bus voltage )	228/240/252 VDC Batteries Qty 19/20/21	Should be variable 228/240 – Batteries Qty 19/20
10	43	Annexure-2 DC CHARACTERISTICS (2- AH capacity of SMF batteries (Exide / Amara Raja / Panasonic)	42 AH X 21 Nos	42 AH X 20 Nos

Amended as per Column (5) is hereby approved and will be treated as the part of bid document.

  
9/10/2015  
System Analyst  
Procuring Entity