

**JAIPUR DEVELOPMENT AUTHORITY, JAIPUR.**

Office of Executive Engineer ROB-RUB-II, Room No. 313 B, CCC Building, JDA Campus,  
Indira Circle, Jawahar Lal Nehru Marg, Jaipur- 302004


No.: JDA/ROB-RUB-II/2016/D-91

Dated : 29-02-16

**Clarification for NIB No. : EE-ROB-RUB-II/06/2015-16**

With reference of the work of Construction of Service roads and Drainage work for proposed Six Lane ROB in Lieu of LC-70, Sitapura, on JP-SWM Railway Line, Jaipur published vide this office NIB No. EE-ROB-RUB-II/06/2015-16 dated 11.02.2016 a typographical error has been observed in respect of BOQ (based on RUIDP BSR 2013) item No 10.10 & 10.20 which has been taken from item No. 16.11 of RUIDP BSR 2013 wherein grade of bitumen has been printed as "PMB-40" due to typographical error.

It is clarified that it should be read as VG-30 in place of PMB-40. The quantity and rates of this item are unchanged.

  
29/02/2016  
**Executive Engineer ROB-RUB-II**  
**J.D.A. Jaipur.**