

**JAIPUR DEVELOPMENT AUTHORITY**

Room No. 234, Main Building Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004  
Telephone: +91-141-2569696 e.mail : xxxxxxxx@jaipurjda.org

No. JDA/E.E/Elect.-III/2016/D-

Date:

**NOTICE INVITING BID**  
**NIB No. : 4(i)/2016-17**

Online Bids are invited up-to 3:00 PM 15.09.2016 for Rate Contract for Addition/Alteration of Traffic Signalization work at various crossing in Jaipur City. . Details may be seen in the Bidding Document at our office or the website of State Public Procurement Portal website [www.sppp.rajasthan.gov.in](http://www.sppp.rajasthan.gov.in), [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) and [www.jaipurjda.org](http://www.jaipurjda.org).

To participate in the bid, bidder has to be:

1. Registered on JDA website [www.jaipurjda.org](http://www.jaipurjda.org)

For participating in the Bid, the Bidder has to apply for the Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security Deposit, online only.

2. Registered on e-Procurement Portal of Government of Rajasthan [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) for online e-Bid submission.

Saleem Ahemad  
(Executive Engineer Elect-III)  
Procuring Entity

# जयपुर विकास प्राधिकरण, जयपुर

इन्दिरा सर्किल जे.एल.एन. मार्ग, जयपुर

क्रमांक / जविप्रा / अधि.अभि. / विद्युत-तृतीय / 2016-17 / डी-

दिनांक:

## बिड सूचना सं. 04 / 2016-17

जविप्रा जोन-(विद्युत-तृतीय) में जयपुर के विभिन्न चौराहों पर दर संविदा के तहत नये ट्रेफिक सिग्नल एवं दुरुस्तिकरण का कार्य के लिए दिनांक 15.09.2016 सायं 3:00 बजे तक ऑन लाईन निविदा आमंत्रित की जाती हैं विस्तृत विवरण, जो कि निविदा प्रपत्र में उपलब्ध है, अद्योहस्ताक्षरकर्ता के कार्यालय में अथवा राजस्थान सरकार के उपापन पोर्टल [www.sppp.raj.nic.in](http://www.sppp.raj.nic.in) व [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) एवं जयपुर विकास प्राधिकरण की वेबसाइट [www.jaipurjda.org](http://www.jaipurjda.org) पर देखी जा सकती है।

निविदादाता को निविदा में भाग लेने हेतु आवश्यक है कि :-

1. जयपुर विकास प्राधिकरण की वेबसाइट [www.jaipurjda.org](http://www.jaipurjda.org) पर पंजीकृत हो। निविदा शुल्क व आर.आई.एस.एल. प्रक्रिया शुल्क केवल ऑन लाईन ही देय होगी। बोली प्रतिभूति ऑनलाईन अथवा बैंक गारन्टी के द्वारा दी जा सकती है।
2. ऑन लाईन निविदा में भाग लेने हेतु राजस्थान सरकार के पोर्टल [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) पर पंजीकृत हो।

अधिशायी अभियन्ता (विद्युत-तृतीय )  
जविप्रा, जयपुर।

## JAIPUR DEVELOPMENT AUTHORITY

Room No. 113, CCC building, Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004  
Telephone: +91-141-2569696 e.mail : xxxxxxxx@jaipurjda.org  
No. JDA/E.E/Elect.-III/2016-17/D- Date:

### NOTICE INVITING BID NIB No. E.E. (Elect.-III)/4(i)/2016-17

<b>Name &amp; Address of the Procuring Entity</b>	<ul style="list-style-type: none"> <li>➤ Name: Executive Engineer (Elect.-III), Jaipur Development Authority</li> <li>➤ Address: Room No. 113, CCC Building, 1st Floor, Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302004 (Rajasthan)</li> <li>➤ Email: saleem119164@Gmail.com</li> </ul>
<b>Subject Matter of Procurement</b>	➤ Rate Contract for Addition/Alteration of Traffic Signalization work at various crossing in Jaipur City.
<b>Bid Procedure</b>	Single Bid (eg. Single-stage Two part (envelope) open competitive) eBid procedure at <a href="http://eproc.raajasthan.gov.in">http://eproc.raajasthan.gov.in</a>
<b>Bid Evaluation Criteria (Selection Method)</b>	➤ L-1 (eg. Least Cost Based Selection (LCBS)-L1)
<b>Period of Work</b>	➤ 12 Months
<b>Websites for downloading Bidding Document, Corrigendum's, Addendums, etc.</b>	➤ Websites: <a href="http://www.sppp.raajasthan.gov.in">www.sppp.raajasthan.gov.in</a> , <a href="http://www.eproc.raajasthan.gov.in">www.eproc.raajasthan.gov.in</a> , <a href="http://www.jaipurjda.org">www.jaipurjda.org</a>
<b>Website for online Bid application and payment *</b>	<ul style="list-style-type: none"> <li>➤ Website: <a href="http://www.jaipurjda.org">www.jaipurjda.org</a></li> <li>➤ For participating in the Bid, the Bidder has to apply for this Bid and pay the Bidding Document Fee, RSL Processing Fee and Bid Security Deposit, online only.               <ul style="list-style-type: none"> <li>○ Bidding document fee: Rs. 1000.00 Rupees (Rupees One Thousand only)</li> <li>○ RSL Processing Fee: Rs. 1000 (Rupees One Thousand only)</li> <li>○ Requisite Bid Security Deposit</li> </ul> </li> </ul>
<b>Estimated Procurement Cost</b>	➤ INR 257.17 Lacs (Rupees Two Crore Fifty Seven Lacs and Seventeen Thousand Only)
<b>Bid Security Deposit</b>	<ul style="list-style-type: none"> <li>➤ Amount (INR) : 2% (Rs. 514340.00) of Estimated Procurement Cost, 0.5% of S.S.I. of Rajasthan, 0.5% (Rs. 128585.00) for Bidder registered as contractor in JDA, 1% for Sick Industries, other than S.S.I., whose cases are pending with Board of Industrial &amp; Financial Reconstruction.</li> <li>➤ BSD can be deposited either online or BG. The bidder will provide details of BG viz No, issuing date, expiring date etc. online tendering system of JDA.</li> <li>➤ The original BG will be physically handed over in JDA as detailed below. A copy of this BG to be attached with the document during uploading.</li> </ul>
<b>Bank details for online/RTGS/NEFT</b>	<ul style="list-style-type: none"> <li>➤ ICICI Bank Ltd.</li> <li>A/c no. 675401700586</li> <li>IFSC code ICIC0006754</li> </ul>
<b>Publishing Date on SPP Portal*</b>	➤ 6.09.2016
<b>Start date:- On JDA Portal Document sale/Download/Bid Participation Amount deposit</b>	➤ 6.09.2016
<b>Start Date:- On eProc Portal of GOR for Bid submission</b>	➤ 6.09.2016 at 5.00 PM
<b>End Date:- On JDA Portal document sale/Download/Bid participation Amount Deposit</b>	➤ 15.09.2016 at 3.00 P.M.
<b>End Date:- On eProc Portal of GOR for Bid Submission</b>	➤ 15.09.2016 at 3.00 PM
<b>Physical BG Submission Start date</b>	➤ 6.09.2016 at 10.00 AM
<b>Physical BG Submission End date</b>	➤ 15.09.2016 at 3.00 PM
<b>Place of submission of physical B.G.</b>	➤ Nodal Officer (Tendering)/Sr. Accounts officer, Room no. MB-SF-225A of Main Building, JDA, Jaipur
<b>Bid opening Date on eProc Portal of GOR</b>	<ul style="list-style-type: none"> <li>➤ 16.09.2016 at 4.00 PM</li> <li>➤ Room No. Room No. CCC –TF-309, Third Floor, CCC Building, Jawahar Lal Nehru Marg, Jaipur 302004 (Rajasthan), 1st Floor, Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004 (Rajasthan)</li> </ul>
<b>Bid Validity</b>	➤ 120 days from the bid submission deadline
<b>JOB No.</b>	➤ <b>132/2016-17</b>

\* The amount is to be deposited online by bidder. In case the amount exceeds the online payment limit the payment may be made through RTGS/NEFT in ICICI BANK LTD Bank Account Number 675401700586 IFSC Code ICIC0006754. After successful payment, update the UTR/Instrument number on JDA Tender portal against the tender you want to participate. The amount deposited will be confirmed by JDA and will be updated online.\*\* There should be a gap of 3 working days **BETWEEN** End Date for Bid Applying, Online Payment & Bid Submission **AND** Bid opening date.

The bidder will also have choice of submitting bid security deposit (98SD) through BG, the bidder will provide details of BG viz. Bank guarantee No, issuing date, expiring date etc. On online tendering system of JDA. However the tender fees and processing charges of RSL continue to be paid through online mode only i.e. Payment Gateway or RTGS/NEFT.

A copy of bank guarantee will be deposit in JDA only after schedule date and time of closing for submission of bid on e-procurement portal of GoR as detailed in NIB.

The physical bank guarantee will be physically handed over to Nodal officer of online tendering system of JDA.

\*\* The Publishing date will be the date of uploading NIB on <http://sppp.raajasthan.gov.in> [वित्त (एस.पी.एफ.सी.) विभाग के आदेश क्रमांक एं. 1(8)वित्त/सविलेनी/2014, दिनांक 31.08.2015 के अनुसार राज्य लोक उपापन पोर्टल (<http://sppp.raajasthan.gov.in>) पर प्रकाशित एन.आई.बी. को ही प्रथम प्रकाशन माना जाएगा और नियमानुसार निर्धारित समय सीमा की गणना पोर्टल पर उक्त प्रकाशन की तिथि, जो की स्पष्टतया निश्चित है, से ही की जाएगी]

**Note:**

1. Bidder (authorised signatory) shall submit their offer on-line in Electronic formats both for technical and financial proposal.
2. In case, any of the bidders fails to pay the Tender Fee, BSD, and RISL Processing Fee, online (subject to confirmation), its Bid shall not be accepted.
3. To participate in online bidding process, Bidders must procure a Digital Signature Certificate (Type III) as per Information Technology Act-2000 using which they can digitally sign their electronic bids. Bidders can procure the same from any CCA approved certifying agency, i.e. TCS, Safecrypt, Ncode etc. Bidders who already have a valid Digital Signature Certificate (DSC) need not procure a new DSC. Also, bidders must register on <http://eproc.rajasthan.gov.in> (bidders already registered on <http://eproc.rajasthan.gov.in> before 30-09-2011 must register again).
4. JDA will not be responsible for delay in online submission due to any reason. For this, bidders are requested to upload the complete bid well advance in time so as to avoid 11th hour issues like slow speed; choking of web site due to heavy load or any other unforeseen problems.
5. Bidders are also advised to refer "Bidders Manual Kit" available at eProc website for further details about the e-Tendering process.
6. Training for the bidders on the usage of e-Tendering System (eProcurement) is also being arranged by DoIT&C, GoR on a regular basis. Bidders interested for training may contact e-Procurement Cell, DoIT&C for booking the training slot.  
Contact No: 0141-4022688 (Help desk 10 am to 6 pm on all working days) e-mail: [eproc@rajasthan.gov.in](mailto:eproc@rajasthan.gov.in)  
Address : e-Procurement Cell, JDA, Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur
7. The procuring entity reserves the complete right to cancel the bid process and reject any or all of the Bids.
8. No contractual obligation whatsoever shall arise from the bidding document/ bidding process unless and until a formal contract is signed and executed between the procuring entity and the successful bidder.
9. Procurement entity disclaims any factual/ or other errors in the bidding document (the onus is purely on the individual bidders to verify such information) and the information provided therein are intended only to help the bidders to prepare a logical bid-proposal.
10. The provisions of RTPPA Act 2012 and Rules thereto shall be applicable for this procurement. Furthermore, in case of any inconsistency in any of the provisions of this bidding document with the RTPPA Act 2012 and Rules thereto, the later shall prevail.

**Saleem Ahmad**  
(Executive Engineer Elect-III)

---

**Process for Participation & Depositing Payment Online**

JAIPUR DEVELOPMENT AUTHORITY, has decided to receive Bidding document fee, RISL Processing Fee and Bid Security Deposit (BSD) through online mode only for which the bidder has to get registered himself on JDA portal [www.jaipurjda.org](http://www.jaipurjda.org).

**To participate in the bid, bidder has to be:**

1. Registered on JDA website [www.jaipurjda.org](http://www.jaipurjda.org) (by depositing Rs. 500.00 online, the validity of which remains 3 (three) years).  
For participating in the Bid, the Bidder has to apply for this Bid and pay the Bid Document Fee, RISL Processing Fee and Bid Security Deposit, online only.
2. Registered on e-Procurement Portal of Government of Rajasthan [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) for online e-Bid submission.

**Methods for depositing on line amount**

- Online through Internet Banking, Debit Card or Credit Card.
- In case the amount exceeds the online payment limit, the payment may be made through RTGS/NEFT/Transfer in Bank Account Number **675401700586** IFSC Code **ICIC0006754** of ICICI BANK Limited, JDA Campus Jaipur.

In case of RTGS / NEFT / Transfer the bidder is required to deposit the requisite amount in the dedicated bank account number as mentioned above and has to get the UTR / Reference number from the bank. This number requires to be updated while applying the bid on JDA portal.

While participation in the bid, a receipt will be generated through the system showing the submission details as per **Annexure-4**. The bidder is required to fill the instrument numbers for various heads on e-Procurement portal [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) as mentioned in the receipt.

More details about Registration Process, Terms and Conditions and FAQ along with contact detail is available on JDA website [www.jaipurjda.org](http://www.jaipurjda.org) under [e-Services](#)>>JDA Tender

Bidder has to submitted as proof of deposited amount against the Bid on e-Procurement Portal

## Jaipur Development Authority

### Bid Participation Receipt

Date & Time : 09/06/2015 05:13 PM

#### Bid Detail

<b>Bid Id :</b> 6215152001	<b>Procurement Entity :</b> XXXXXXXXXXXXX
<b>Bid Title :</b> Testing	
<b>Bid Value :</b> 300000	<b>Bid Opening Place :</b> Manthan Hall, Jaipur Development Authority

#### Bidder Detail

Name of Entity :	XXXXXXXXXXXX	Mobile:	9829012345
Registration Type:	Individual	Instrument Amount :	32500.00
Payment Mode:	Online/UTR	Payment Channel :	Payment Gateway/ICICI Branch - JDA
Instrument No :	456123789	Instrument Date :	17-06-2015

#### Dates Detail

Sr. No.	Event Name	Event Date
1	Publishing Date	01/06/2015 01:00 PM
2	Bid Opening Date	01/07/2015 03:00 PM

#### Specific Instrument Detail for eProc Rajasthan

<b>Instrument Type:</b> DD			
Instrument Number	Head Name	Amount	Date
10000	Tender Fee	400.00	05/06/2015
10001	RISL Processing Fee	1000.00	05/06/2015
10002	Bid Security Deposit	30,000.00	05/06/2015
<b>Issuer Detail :</b> Jaipur Development Authority		<b>ChallanNumber:</b> 641515600014	

**SCHEDULE 'A' : INFORMATION USE FULL FOR THE CONTRACTORS:**

The bidder should see the site and fully understand the condition of the site before bidding and include all lead, lifts etc. for the material in his item rate / percentage to the quoted on the rates as given in schedule 'G'. Then work shall be carried out in accordance with the Rajasthan PWD specification for electric works 1980 and to the entire satisfaction of the Engineer-Incharge of the work.

**SCHEDULE 'B': LIST OF THE DRAWING TO BE SUPPLIED BY THE DEPARTMENT:**

The drawing may be seen in office of the undersigned.

**SCHEDULE 'C' : LIST OF THE DRAWING TO BE SUPPLIED BY THE CONTRACTOR:**

List of the drawing to be supplied by the contractor Nil. But the contractor shall have to arrange drawings required for the work at his own cost after deposition necessary cost within JDA.

**SCHEDULE 'D': TEST OF THE MATERIALS:**

The test of the material and workmanship shall be conducted by the JDA staff as necessary. The result of such tests should confirm to be standard laid down in the Indian standards and or the standards laid down in the detailed specification of the Public Works

Deptt. proper quality control is required to be maintained by the contractor. Qualified personnel as required under the contractor enlistments rules duly approved by the Deptt. shall have to be engaged at site by the contractor. The Deptt. reserves the right to engage such staff and recover the expenses from the contractor on such account in case of his failure to do so.

**SCHEDULE 'E': SAMPLES OF THE MATERIALS:**

The samples of the material to be used by the contractor shall be deposited 15 days in advance with the Engineer In-charge and be got approved by him before use.

**SCHEDULE 'F': TIME OF COMPLETION:**

The work should start within 15 days of issue of work order and completion within months/days.

**SCHEDULE 'G': ATTACH SEPARATELY SCHEDULE 'G' BASED ON 2016 JDA BSR (Elect) RAJASTHAN JAIPUR/JDA APPROVED.**

**SCHEDULE 'H': SPECIAL CONDITION ATTACHED SEPARATELY.**

**SCHEDULE 'I': LIST OF THE MATERIAL TO BE SUPPLIED BY THE DEPTT.**

Whatever material available in JDA store shall be issued @ the prevailing store issue date of JDA + 5% storage charges at the time of issue of cement.

Signature of Contractor  
with full address.

Executive Engineer (Elect.-III)  
JDA, Jaipur.

# **JAIPUR DEVELOPMENT AUTHORITY, JAIPUR**

## **Special Terms & Conditions for traffic light work.**

1. Traffic signalization system in Jaipur City is based in CDAC software (Centre for Development automation of computers (A Govt. of India Enterprises) and its Technology so it necessary that bidder should be a technology partner of CDAC or having authorization to use CDAC technology & having original software's of CDAC (copy of authorization certificate to be attached) i.e. CoSiCoS software.
2. The Bidder should be Technology Partner of CDAC for Area Traffic Control Systems (ATCS) and have experience of execution of ATCS work in the Past. Required documents are to be attached with Bid.
3. The bidder should have provision in it's new system work to connect the new traffic signals and cameras (to be provided) with existing old system of traffic signalization which is based on CDAC Software at its control room located at Yadgar Police control, without taking any extra charges, Connectivity charges if required will be paid extra by JDA.
4. The Bidder should have experience of Maintenance of ATC System successfully for two years.
5. Those bidders whose bid does not fulfill above conditions their bid shall be rejected.
6. The Contractor has to give the performance guarantee of the following materials for the period mentioned against them from the date of completion of work:

UTCS Controller	12 Months
All types of LED's	12 Months
Traffic Cameras	12 Months
Cantilever Swaged Pole	12 Months
All types of cables	18 Months

7. The above performance guarantee has to be submitted to Executive Engineer (Electrical-III) on Non-Judicial Stamps of Rs.100/- duly attested by Ist class Magistrate/Notary Public.
8. The Contractor has to arrange for the permission for the charging of electrical system/New Electric connection from the Electrical inspector Govt. of Rajasthan/JVVNL. He will have to deposit the necessary fees, which shall be reimbursed by Jaipur Development Authority.
9. The Contractor will coordinate for charging process the system, handling over the system and if any defects, is pointed out by the RSEB/JVVNL/PWD, then he will have to rectify the same.
10. Inspection of material shall be bear by the contractor it self, including expenditure of 'to & fro' journey & Stay arrangements.
11. The material shall be purchased from the firms, which are also supplying the material to RSEB/JVVNL/PWD.
12. All HT/LT cables should be sequentially marked with cable size & length duly embossed.
13. DLP period for various type of above works will now be governed by Director (Engineering-I) office order no. 29 dated 11.03.2016 (Copy Enclosed named by DLP period)

**Executive Engineer (Elect-III)**  
**JDA, Jaipur**

I carefully study & do agree for above terms & Conditions.

Signature & Seal of the Contractor



# JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

## SPECIAL CONDITION

### SCHEDULE 'H'

01. If there is any typographical error or otherwise in the 'G' Schedule the rates given in the relevant BSR on which schedule 'G' has been prepared, shall prevail.
02. Special Conditions of Contract regarding Defect Liability Period (DLP) for Roads works costing Rs. 25.00 lacs and more shall be applicable
03. The contractor shall follow the contractor labour regulation and abolition Act 1970 & Rule 1971.
04. The JDA shall have right to cause on audit and technical examination of the work and the final bills of the contractor including all supporting vouchers, abstract etc. to be made within two years after payment of the final bills and if as a result such audit any amount is found to have been over paid/excess in respect of any work done by the contractor under the contract or any work claimed by him to have been done under this contract and found not to have been executed the contractor shall sum from him in ; the manner prescribed in special condition no. 8 or any other manner legally permissible and if it is found that the contractor was paid less then that was due to him under the contract in respect of any work executed by him under it, the amount of such under payment shall be paid bay the JDA to the contractor.
05. The contractor shall not work after the sunset and before sunrise without specific permission of the authority Engineer.
06. Whenever any claim against the contractor for the payment of a sum of money arises out or under the contracts, the JDA shall be entired to recover the sum by appropriating in part or whole of the security deposit of the contractor. In the event of the security being insufficient of if no security has been taken from the contractor then the balance of the total sum recoverable as the case may shall be deducted from any sum then due or which a any time there contract with the JDA should this sum be sufficient to recover the full amount recoverable, the contractor shall pay to JDA on demand the balance remaining due. The JDA shall further have the right to effect such recoveries under P.D.R. Act.
07. The rate quoted by the contractor shall remain valid for a period of 4 (Four) months from the date of opening of the tenders.
08. By submission of this tender the contractor agree to abide with all printed conditions provided in the PWD manual from 64 (Chapter 3-para 36) and subsequent modification.
09. No conditions are to be added by the contractor and conditional tender is liable to be rejected.
10. All transaction in the execution of this work and this tender will be liable to sale-tax vide section 2(B) read with sub clause (4) Sale-tax Rule, 1954.
11. If any bidder withdraws his tender prior to expiry of said validity period given at S. No. 7 or mutually extended prior or makes modifications in the rates, terms and conditions or fails to the tender within the said period, which are not acceptable to the department or fails to commence the work in the specified period, fails to execute the agreement and fails to furnish performance guarantee the department shall, without prejudice to any, other right or remedy, be at liberty to forfeit the amount of earnest money given in any from absolutely. If

any contractor, who having submitted a tender does not execute the agreement or start the work or does not complete the work and the work has to be put to retendering, shall stand debarred for 6 Months from participating of tendering in JDA in addition to forfeiture of Earnest Money/Security/Performance Guarantee and other action under agreement.

12. The contractor shall arrange his own machinery required for the work.
13. The contractor shall arrange his own storage, yard of sufficient capacity for storing wherever supplied by the department.
14. Rules regarding enlistment of contractors provide that work ; upto five times limit for which they are qualified for tendering can be allotted to them Therefore, before tender the contractors will keep this in mind, and submit the details of work. Tenders with incomplete or incorrect information are liable to be rejected.
15. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-In charge in writing. Failing which, such material shall be removed by the Engineer-In charge at risk and the contractor after expiry of 3 days period.
16. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed, fully on the work.
17. None of the permanent works shall be carried out during night or Sunday or any authorized holiday without permission in writhing of the Engineer-In charge.
18. **The contractor shall be fully responsible to follow safety code as per IS 3764:1992 (upto date). The work should be executed without damaging existing water pipe line, LT/HT electric under ground cable, poles, existing surface drain, water connection, Telephone cables etc. In case of any damages the penalty/ liability imposed for such work shall be borne by the contractor and shall be got repaired immediately by arranging material/ labor/ assistance etc. In case of delay JDA reserve right to execute/ get executed the work at the cost and risk of the contractor.**
19. The contractor/firm or company will display necessary signboards & lights from safety point on view during nights at site of work on his own cost as directed by the authorized Engineer In charge.
20. The surplus earth & damaged materials will be immediately removed from the site of work & dumped as per instruction of Engineer In charge.
21. No extra payment will be made to the contractor on account of clearance of soakage well/septic falling in the alignment of overhead or underground line.
22. The onus of safety and security of men and material at work including the road user shall be completely of the contractor only.
23. The rate provided in tender documents is inclusive of all Taxes & royalty.
24. The bidder are required to furnish the following documents along with the tender:
  - i. Duly executed power of attorney in original along with two certified copies in the name of the tender's authorized representative to act on behalf of the tenderer and the power tro agree to refer dispute to arbitration.
  - ii. Sales Tax & Income-Tax clearance certificate.
  - iii. Construction programme of work in the form of bar charts.
  - iv. Financial resourced with particulars.
  - v. Constitution, capital, registration, place of business of the tenderer.

- vi. Particulars of registration with central or State Government Organization if any.
  - vii. Details of work of similar type and magnitude already carried out by the tender.
  - viii. Details of work Tendered for and as on the date of issue of tender.
  - ix. Details of Plant machinery available with the tender for this work.
  - x. Details of plant machinery proposed to be used on the work; but not immediately available.
  - xi. **Details of qualified technical personnel proposed to employed on the work.**
  - xii. A declaration to the effect that the tenderer is engineering construction firm or any associate of such firms which has successfully carried out large works of this nature and have adequate organization and experienced personnels to handle the present work.
  - xiii. Copies of certificates if any.
25. No extra load of earth / material shall be paid over and above as specified in 'G' Schedule. Source/ borrow Pit area for earth shall have to be arranged by the Contractor at his own cost.
26. Undersigned has full right to reject any or all tenders without given any reasons.
27. It is a mandatory condition that contractor will get all insulated material tested from CTL of JVVNL before using it at site.
28. All the provision of the RAJASTHAN TRANSPARENCY IN PUBLIC PROCURMENT ACT,2012 AND RULES, 2013 WILL BE APPLICABLE. IF THERE IS ANY CONTRADICTIONS IN EXISTING SPECIAL CONDITIONS AND PROVISION OF THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCURMENT ACT,2012 AND RULES, 2013 SHALL BE APPLICABLE.

**SIGNATURE OF CONTRACTOR**  
**WITHFULL ADDRESS:**

**EXECUTIVE ENGINEER (Elect.III),**  
**JDA, JAIPUR**

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR  
**Special Terms & Conditions for Electrification work.**

The Contractor has to give the performance guarantee of the following materials for the period mentioned against them from the date of completion of work:

(a)	Transformers	30 Months
(b)	All types of Insulators	18 Months
(c)	ACSR Conductors	6 Months
(d)	Isolators	6 Months
(e)	Horn gap fuse set	6 Months
(f)	LT Pillar Box	6 Months
(g)	All types of HT/LT cables	18 Months

1. DLP period for various type of above works will now be governed by Director (Engineering-I) office order no. 29 dated 11.03.2016 (Copy Enclosed named by DLP period)
2. The Contractor has to arrange for the permission for the charging of electrical system from the Electrical Inspector Govt. of Rajasthan. He will have to deposit the necessary fees, which shall be reimbursed by Jaipur Development Authority.
3. The contractor will coordinate for the system handing over and charging process and if any defects, is pointed out by the RSEB/JVVNL/PWD/JNN, then he will have to rectify the same.
4. The final bill shall be paid after the lines and substations are handed over to RSEB/JVVNL/PWD/JNN and system is charged.
5. Inspection shall be bear by the contractor it self.
6. The material shall be purchased from the firms, which are also supplying the material to RSEB/JVVNL.
7. All HT/LT cables should be sequentially marked with cable size & length duly embossed.
8. The contractor shall return unused material issued to him by the deptt. If desired by the Engineer in-charge and in case, of failure to do so he shall be charged for such unreturned material at double the issue rate including storage and supervision charges or the market rate whichever is higher. The basis of the theoretical consumption and allowing for wastage @ 5% at double the issue rate including storage and supervision charges or market rate which ever is higher.
9. **The contractor shall be fully responsible to follow safety code as per IS 3764:1992 (upto date). The work should be executed without damaging existing water pipe line, LT/HT electric under ground cable, poles, existing surface drain, water connections, Telephone cables etc. In case of any damages the penalty/ liability imposed for such work shall be borne by the contractor and shall be got repaired immediately by arranging material/ labor/ assistance etc. In case of delay JDA reserve right to execute/ get executed the work at the cost and risk of the contractor.**
10. It is a mandatory condition that contractor will get all insulated material tested from CTL of JVVNL before using it at site.

**Executive Engineer (Elect.-III)**  
**JDA, Jaipur**

I carefully study & do agree for above terms & Conditions.  
Signature & Seal of the Contractor

# JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

## DETAILED SPECIAL CONDITION AND SPECIFICATIONS

1. The scope of the Schedule 'H' and 'G' comprises HT/LT Line work on the road mentioned in schedule 'G'
2. The tubular poles are proposed to be erected generally in the median strip of the road or sides unless otherwise instructions are given to change the alignment.
3. The road in question in national, highway / important only road and as not only heavy traffic passes through the road but all the VIPs also pass through it the before it will be the contractor responsibility the provide all retardared caution signs during the execution of work at his own cost in order in to avoid any mis-happening.
4. No opening shall be left uncovered during night. The tenderer shall make all arrangement to avoid any claim if preferred on his account shall be the liability of the tenderer.
5. No road or part of the road shall be cut without taking the prior permission in writing from the competent authority. The permission shall be arranged by tenderer on the request of JDA. However, any changes will be borne by JDA.
6. The contractor shall be deemed to have carefully examined the specifications general condition and tender drawing etc. and they have been fully informed and have satisfied himself as to the nature and character of the work to be executed site conditions and other relevant matters and details.
7. References to standard code specifications recommendation shall mean the attested addition of such publications of the work to be executed at site before the date of invitation to submit proposals.
8. The excavated material shall be place within 1.5 Mtr. of the edge the half of the depth of the trench with have is more site clear shall be done within 24 hours.
9. The work shall be carried out strictly domplying within Indian Electricity Rules in forces and as per specifications for Electrical work issued by PWD Raj., Jaipur 1980.
10. **Trenching:** The trenches shall be of shaper size as instructed by the Engineer-In-Charge.
  - (a) **Width**
    - (i) The minimum width of trench for laying single cable shall be 35 Cm.
    - (ii) Where more than one cable is to be laid in the same trench in horizontal formation. The width of the trench shall be increased such that the spacing between the cable shall be at least 20 Cm.
  - (b) **Depth:**
    - (i) Where cable core laid in single tier formation in the total depth of shall not be less than 75 cm for cable upto 1.1 KV.
    - (ii) When more than one tier of cable is unavoidable and vertical formation of laying is adopted depth of trench in (i) above shall increases by 30 cm for each additional tier to be formed.
    - (iii) The depth shall be 1.0 Mtr. of 11 KV, 1.5 Mtr. For 33 KV.
  - (c) **Excavation**

The trench must be excavated straight and if it is necessary to give band or curve radius of such trench shall be at least 12 time the over all dia meter of the cable.
  - (d) **Placing of the Cable**

The cable must be places in the trench on band of fine sand of 8 cm thick bed, and the cable shall be laid below water and sewer lines.
  - (e) For the safe guard of cable it must have covering of clean dry rever sand or any other type of soil as directed by Engineer-In-Charge in not less than 17 cm.
  - (f) **Protection**

To protect the cable against mechanical damages the second class bricks or stone katla as specification shall be placed over the cable width wise.
11. Satisfactory type/acceptance test that results wherever applicable conducted from Govt./Govt. approved laboratory as per ISS shall be submitted prior to use. The routine tests of cable shall be conducted only after delivery at site at his own cost.
12. The HPSV luminaries with bulbs supplied by the department at free of cost and the same shall be collected from JDA stores kept at site with proper handing at his own cost. It shall be installed by the contractor in perfect working order on the tubular poles as per the instructions of the site with In-charge.

13. **Earthing**  
The ground Earthing shall be done generally confirming to IS specification of 3043-1966 all the work earth terminal be provided duly crimped/soldered.
14. **Controlling Panels**  
The controlling panels such as main panel service pillar box and fuse boxes are to be installed in span. The rubber gasket bedding of high quality rubber is to be provided around all operable parts. The all hard works should be made corrosion resistant giving all chemical treatment before its fabrication and before final coat desired colour painting and red oxide primer should be applied. All internal connectives are be made with PVC insulated copper conductor with copper lugs dully crimped. The internal wiring shall be arranged with clips the bus bars and connection shall consists of drawn high conductivity copper strip with PVC 3 leaves tops of phase colours.
15. **Submission of drawing by the contractor**  
The following two drawing are required to be submitted by the contractor.
  - (i) **Main Panel Drawing:** The Contractor shall submit the drawing of main panel all dimensions all internal connection of diagram, well before its fabrication and obtain prior approval of the drawings from the competent authority.
  - (ii) **Completion drawings:** The contractor shall submit the completion drawings of the project showing the roots of the cable and position of panel etc.
16. **Testing**  
The following test shall be performed by the contractor at his own cost.
  - (i) **Continuity and installation test of cable:** The contractor shall arrange for the continuity of cable for well use of the perfect of the cable.
  - (ii) **Megar Testing:** The whole installation shall be arranged to be test by contractor after its completion shall in presence of Engineer-In-Charge and results shall be recoated and singed jointly.
17. **Earthing Testing:** Earth test shall be performed by the contractor and results will be used be recorded and signed jointly.
18. Any other test for cable etc. required shall be arranged by the contractor.
19. Conditions given in the bid from apply in full.
20. The contractor shall have to obey the labour laws. The labour shall have to pay monthly and shall have first line on the bill of contractor, in case of complaint of labour and non payment of wages is received to the department.
21. The rate of every item should be quoted against each in figures and in words as well for complete Non BSR Items.
22. In case of any typographical error in nomenclature, unit and rate, the rates as per BSR on which 'G' Schedule is prepared shall be binding on the tenders.
23. In case of any dispute the Zone Engineer (Electrical) decision shall be final.
24. The tenderers are expected to be fully conversant with the general and special conditions of contract in force in this office. They must see the site of work acquaint themselves of the position of the materials. Fluctuation of the rates in the market, see the schedule and plans in the office and remove doubts, if any, before submitting their tenders.
25. The JDA is not responsible for arranging any material whatsoever any the contractor will have to complete the work within the specified time with specified material and approved accessories, from the stock, non-availability of material or delay in the consignment will not be entertained to as an excuse for extension of time for completion of work.
26. Contractor will not be paid extra for sales or any other tax.
27. Bid must be submitted on the prescribed forms duly signed by the tenderers on every page.
28. All entries by the bidders should be in on ink only. Erasers and over writings are not permissible. All cancellation correction and insertions must be signed by the tenderer.
29. Rate quoted should be given for the work, separately in words and figures in case there is any difference in rates between words and figures the lower of the two will be taken as correct.
30. All the papers signed by the parties to this contract and bond together and sealed shall deemed to from part of the contract bond and shall be read as conditions of contract.
31. In every case in which by virtue for the provisions of section 12 sub section (I) of the workman's Compensation Act. 1923 cost is obliged to pay compensation to a workman employed by the contractor of by a sub contractor for execution to said work Govt. will recover from the contractor the amount of the compensation paid and without prejudice to the rights of Govt. under section 12 sub section (2) of the said Act, Govt. shall be at liberty to recover such amount or any part there of by deducting if from the earnest mony deposited by the contractor to his credit or any other sum due by Govt. to the contractor whether under this contract or other wise.

32. The contractor shall arrange the electric connection from concern electric supply company at his own before release of the final Bill. However, any fee to be paid on this account shall be paid by the JDA.
33. The contractor shall arrange the certificate from electric inspector on completion of the electric installation at his own. However, any fee to be paid on this account shall be paid by the JDA.
34. The entire material of Schedule 'G' & specified main materials of schedule 'H' shall be inspected / tested at manufacturing site by an officer not below the rank of sector Engineer and the cost of inspection shall be borne by the contractor itself.

I/We have carefully study the instructions / conditions mentioned above & do hereby undertake to agree for the same.

**SIGNATURE OF CONTRACTOR  
WITHFULL ADDRESS:**

**EXECUTIVE ENGINEER (Elect.-III),  
JDA, JAIPUR**

Note:-

1. किसी भी निविदा को बिना कारण बताये निरस्त किया जा सकता है।
2. आवेदक / संवेदक को निविदा प्राप्त करने के लिये आवेदन के साथ पंजीयन प्रमाण पत्र की प्रति प्रस्तुत करना अनिवार्य है।
3. आवेदक / संवेदक को निविदा प्रपत्र पर अपना पता एवं दूरभाष नम्बर अंकित करना अनिवार्य है।

## **Annexure A : Compliance with the code of Integrity and No Conflict of Interest**

Any person participating in a procurement process shall –

- (a) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in procurement process or to otherwise influence the procurement process;
- (b) Not misrepresent or omit the misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (c) Not indulge in any collusion, Bid rigging or anti-competitive behavior to impair the transparency, fairness and progress of the procurement process;
- (d) Not misuse any information shared between the procuring Entity and the Bidders with an intent to gain unfair advantage in the procurement process;
- (e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (f) Not obstruct any investigation or audit of a procurement process;
- (g) Disclose conflict of interest, if any; and
- (h) Disclose any previous transgressions with any Entity in India or any other country during the last three years or any debarment by any other procuring entity.

### **Conflict of Interest :-**

The Bidder participating in a bidding process must not have a Conflict of interest. A conflict of interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

- i. A Bidder may be considered to be in Conflict of Interest with one or more parties in a bidding process if, including but not limited to:
  - a. Have controlling partners/shareholders in common ; or
  - b. Receive or have received any direct or indirect subsidy from any of them; or
  - c. Have the same legal representative for purposes of the Bid; or
  - d. Have a relationship with each other; directly or through common third parties, that puts them in a position to have access to information about or influence on the Bid of another Bidder, or influence the decisions of the Procuring Entity regarding the bidding process; or



- e. The Bidder participates in more than one Bid in a bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which the Bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one Bid; or
- f. The Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the Goods, Works or Services that are the subject of the Bid; or
- g. Bidder or any of its affiliates has been hired (or is proposed to be hired) by the Procuring Entity as engineer-in-charge/ consultant for the contract.

## **Annexure B : Declaration by the Bidder regarding Qualifications Declaration by the Bidder**

In relation to my/our Bid submitted to ..... for procurement of  
..... in response to their Notice inviting Bids No.  
.....Dated ..... I/We hereby declare under Section 7 of Rajasthan  
Transparency in Public Procurement Act, 2012, that :

1. I/We possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entity;
2. I/We have fulfilled my/our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the Bidding Document;
3. I/We are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have my/our business activities suspended and not the subject of legal proceeding for any of the foregoing reasons;
4. I/We do not have, and our directors and officers not have, been convicted of any criminal offence related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement Contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/We do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Date :

Signature of bidder

Place :

Name :

Designation :

Address :

## **Annexure C : Grievance Redressal during Procurement Process**

The designation and address of the First Appellate Authority is ACE (Elect), JDA Jaipur

The designation and address of the Second Appellate Authority is JDC, JDA, Jaipur

### **(1) Filing an appeal**

If any Bidder or prospective bidder is aggrieved that any decision, action or omission of the Procuring Entity is in contravention to the provisions of the Act or the Rules or the Guidelines issued thereunder, he may file an appeal to First Appellate Authority, as specified in the Bidding Document within a period of ten days from the date of such decision or action, omission, as the case may be, clearly giving the specific ground or grounds on which he feels aggrieved: Provided that after the declaration of a Bidder as successful the appeal may be filed only by a Bidder who has participated in procurement proceedings: Provided further that in case a Procuring Entity evaluates the Technical Bids before the opening of the Financial Bids, an appeal related to the matter of Financial Bids may be filed only by a Bidder whose Technical Bid is found to be acceptable.

(2) The officer to whom an appeal is filed under para (1) shall deal with the appeal as expeditiously as possible and shall endeavour to dispose it of within thirty days from the date of the appeal.

(3) If the officer designated under para (1) fails to dispose of the appeal filed within the period specified in para (2), or if the Bidder or prospective bidder or the Procuring Entity is aggrieved by the order passed by the First Appellate Authority, the Bidder or prospective bidder or the Procuring Entity, as the case may be, may file a second appeal to Second Appellate Authority specified in the Bidding Document in this behalf within fifteen days from the expiry of the period specified in para (2) or of the date of receipt of the order passed by the First Appellate Authority, as the case may be.

#### **(4) Appeal not to lie in certain cases**

No appeal shall lie against any decision of the Procuring Entity relating to the following matters, namely :-

- (a) Determination of need of procurement;
- (b) Provisions limiting participation of Bidders in the Bid process;
- (c) The decision of whether or not to enter into negotiations;
- (d) Cancellation of a procurement process;
- (e) Applicability of the provisions of confidentiality.

#### **(5) Form of Appeal**

- (a) An appeal under para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal.
- (b) Every appeal shall be accompanied by an order appealed against, if any, affidavit verifying the facts stated in the appeal and proof of payment of fee.
- (c) Every appeal may be presented to First Appellate Authority or Second Appellate Authority, as the case may be, in person or through registered post or authorized representative.

#### **(6) Fee for filing appeal**

- (a) Fee for first appeal shall be rupees two thousand five hundred and for second appeal shall be rupees ten thousand, which shall be non-refundable.
- (b) The fee shall be paid in the form of bank demand draft or banker's cheque of a Scheduled Bank in India payable in the name of Appellate Authority concerned.

#### **(7) Procedure for disposal of appeal**

- (a) The First Appellate Authority or Second Appellate Authority, as the case may be, upon filing of appeal, shall issue notice accompanied by copy of appeal, affidavit and documents, if any, to the respondents and fix date of hearing.
- (b) On the date fixed for hearing, the First Appellate Authority or Second Appellate Authority, as the case may be, shall,-
  - (i) Hear all the parties to appeal present before him; and
  - (ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.
- (c) After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the Appellate Authority concerned shall pass an order in writing and provide the copy of order to the parties to appeal free of cost.
- (d) The order passed under sub-clause (c) above shall also be placed on the State Public Procurement Portal.

**FORM No. 1**

[See Rule 83]

**Memorandum of Appeal under the Rajasthan  
Transparency in Public Procurement Act, 2012**

Appeal No. .... of .....

Before the ..... (First/Second Appellate Authority)

1. Particulars of appellant :

(i) Name of the appellant :

(ii) Official address, if any :

(iii) Residential address :

2. Name and address of the respondent (s) :

(i)

(ii)

(iii)

3. Number and date of the order appealed against and name and designation of the officer/authority who passed the order (enclose copy), or a statement of a decision, action or omission of the Procuring Entity in contravention to the provisions of the Act by which the appellant is aggrieved:

4. If the Appellant proposes to be represented by a representative, the name and postal address of the representative:

5. Number of affidavits and documents enclosed with the appeal :

6. Grounds of appeal : .....

(Supported by an affidavit)

7. Prayer : .....

Place .....

Date .....

**Appellant's Signature**

## **Annexure D : Additional Conditions of Contract**

### **• Correction of arithmetical errors**

Provided that a Financial Bid is substantially responsive, the Procuring Entity will correct arithmetical errors during evaluation of Financial Bids on the following basis:

- i. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Procuring Entity there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- ii. If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected and . If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated Bid does not accept the correction of errors, its Bid shall be disqualified and its Bid Security shall be forfeited or its Bid Securing Declaration shall be executed.

### **2. Procuring Entity's Right to Vary Quantities**

- (i) If the Procuring Entity does not procure any subject matter of procurement or procures less than the quantity specified in the Bidding Document due to change in circumstances, the Bidder shall not be entitled for any claim or compensation except otherwise provided in the Conditions of Contract.
- (ii) On repeat order for extra items for additional quantity may be placed if it is provided in the bidding documents on the rates and conditions given in the contract, if the original order was given after inviting open competitive bids. Delivery or completion period may also be proportionately increase. The limits of repeat order shall be as under.
  - (a) 50% of the qty of the individual items and 50% of the value of original contract in case of works and
  - (b) 50% of the value of goods or services of the original contract.

### **3. Dividing quantities among more than one Bidder at the time of award (In case of procurement of Goods)**

As a general rule all the quantities of the subject matter of procurement shall be procured from the Bidder, whose Bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the Bidder, whose Bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, in such cases, the quantity may be divided between the Bidder, whose Bid is accepted and the second lowest Bidder or even more Bidders in that order, in a fair, transparent and equitable manner at the rates of the Bidder, whose Bid is accepted.

**SPECIAL CONDITIONS OF CONTRACT REGARDING  
DEFECT LIABILITY PERIOD (DLP) FOR ROADS/ ELECTRICALS WORKS**

As per the decision taken in the 201<sup>st</sup> meeting of Executive Committee held on 23.02.2016 w.r.t. agenda no. 201:22, DLP period of various natures of works amounting more than Rs. 25 lakhs has been revised as per following time periods based on nature of works.

This order will supersede the earlier orders issued in this regard i.e. order No. JDA/TA to D(E)/2010-11/D-317 dated 28.04.2011 including Special Condition No. 2.2.2 & 2.2.3 of Annexure-I related to SD refund & forfeiture (other Special Condition of annexure-I of this order will remain valid) and order No. JDA/Ex.En.(Pr.-5 & TA)/2013/D-43 dated 27.02.2013 and also all pertaining orders, in contract agreements or in PWF&AR having DLP period different than what is being enforced through this present order for concerned type of work.

Table-I

S.No.	Type of work	Existing DLP Period	As per approved in E.C. held on 23.02.2016
1.	Bridge Work	3 years	5 Years
2.	CD Work	3 years	5 Years
3.	CC Road. PQC Work	3 years	5 Years
4.	CC tiles/Kerbs/medians	3 years	5 Years
5.	Drains	6 Months	3 Years
6.	Roads		
	(i)Two layer WBM/GSB	3 years	6 months or one full rainy season which ever is later
	(ii)For Renewal/Strengthening		
	(a)BT upto 30 mm thickness	3 years	1 Years
	(b)BT above 30 mm to upto 40 mm	3 years	2 Years
	(c)BT above 40 mm to upto 90 mm	3 years	3 Years
	(d)BT above 90 mm thickness	3 years	5 Years
	(iii) New Roads		
	(a) BT upto 90 mm	3 years	3 Years
	(b) BT more than 90 mm	3 years	5 Years
7.	Compound wall	6 Months	3 Years
8.	Building Work		
	(i) Work pertaining to Sanitary work electrical works, Joinery works and painting works.	6 Months	2 Years
	(ii) Work pertaining to Building structure and other civil works	6 Months	5 Years
9.	Electric work except maintenance	6 Months	3 years
10.	Sewer/Water supply all including STP and water supply related work except maintenance works.	6 Months	3 Years

The release of SD amount shall be as per following table :-

**Table-II**

<b>S.No.</b>	<b>DLP Period \ Released SD</b>	<b>1 Year</b>	<b>2 Years</b>	<b>3 Years</b>	<b>5 Years</b>
<b>1.</b>	<b>Upto 1 year</b>	<b>100%</b>	<b>40%</b>	<b>20%</b>	<b>10%</b>
<b>2.</b>	<b>Upto 2 year</b>		<b>60%</b>	<b>20%</b>	<b>10%</b>
<b>3.</b>	<b>Upto 3 year</b>			<b>60%</b>	<b>10%</b>
<b>4.</b>	<b>Upto 4 year</b>				<b>20%</b>
<b>5.</b>	<b>Upto 5 year</b>				<b>50%</b>

Various condition for managing DLP are as under :-

- (i) At the time of completion of work, final componnt shall be worked out for each individual item like BT/CC/tiles/ drains etc (as per different categories in Table-I), DLP shall be operative based upon type of individual item ex:- CC-5 years, BT1/2/3/5 years, Drain-3 years etc.
- (ii) Similarly for all new works, these components should be calculated at the time of TS itself, which should be made part of BID document.
- (iii) If any work, amount is less than Rs. 25 lacs but later on due to extra/excess work, if amount of final work cresses more than Rs. 25 lacs, DLP shall be operative as per rule for each individual items.
- (iv) Similarly if any work is more than Rs. 25 lacs but after finalization amount or work is less than Rs. 25 lacs, DLP should be operative for six months or rainy season whichever is late.
- (v) During DLP period if contractor fails to repair any work even after issue of 7 days written notice, same work shall be got executed by respective Executive Engineer at the contractor's risk and cost. This process shall be applicable throughout the DLP period. After completion of DLP period in such works contractor should be debarred and blacklisted. From JDA for three years as per RTPP rule 2012 and 2013 where he defaults twice in a single agreement or in two different works.
- (vi) Quarterly Inspection as per rules shall be carried out and DLP registers shall be maintained by respective Executive Engineers to monitor the DLP repairs.
- (vii) Special and regular inspection shall also be carried out as per order no. JDA/Ex.En. & TA to DE-I/2014-15/D-223 dated 12.03.2015 and order no. SE (PMGSY) CIRULAR 2006/D-115 dated 04.05.2006 Point no. 3.
- (viii) In case JDA feels to take up work on any existing DLP road due to any reason, following procedure should be adopted:
  - (a) At the time of withdrawal total liability of repairs as per DLP conditions to be carried out and contractor shall be asked to complete the same. After completion of assessed repairs DLP period shall be released after deduction amt. as per table III



**Table-III**

<div>% Recovery on withdrawal of DLP of work order</div> <div>DLP period</div>	1 Year	2 Year	3 Year	4 Year	5 Year
1 Year	1.12	-	-	-	-
2 Year	2.55	1.43	-	-	-
3 Year	4.38	3.26	1.83	-	-
5 Year	9	7.88	6.45	4.62	2.47

Note :- Calculation is to be done on quarterly basis.

- (b) In case Contractor fails to carry out these repairs, same shall be carried out at his risk and cost. If the total amt. of such repairs works out to be more than total retained amt. of SD same shall be recovered from other works and as per PDR rules. The amount as per Table III is also to be deducted in addition to this amount.
- (ix) Based upon type of work, DLP conditions for works to be carried out during DLP period with their frequency of respective type of work shall be prepared by respective SE"s after approval of these periods.

This order shall come in force with immediate effect and will be applicable on all new works whose NIB is to be called.

Signature of contractor with  
Full address.

**Executive Engineer –(Elect-III)**  
**JDA, Jaipur.**

## Bank Guarantee Performa for Bid security deposite

Form of (Bank Guarantee) -En cashable at branch of the bank in Jaipur City.

To  
Secretary,  
Jaipur Development Authority,  
Jaipur

Sub:

Bank Guarantee No. \_\_\_\_\_ dated \_\_\_\_\_ for [amount of Security in figures] [in words] on behalf of \_\_\_\_\_ [Name of the Bidder] against the Security Deposit for the work of “Construction of B/T roads in Zone-17,PRN area, JDA, Jaipur (Phase-IV) (Annual Rate Contract).”

WHEREAS, \_\_\_\_\_ [name of Bidder with address] (**hereinafter called “the Bidder”**) has submitted his Bid dated .....for the work of “Construction of B/T roads in Zone-17,PRN area, JDA, Jaipur (Phase-IV) (Annual Rate Contract).” (**Name of Work**) (Hereinafter called “the Bid”).

KNOW ALL PEOPLE by these presents that we \_\_\_\_\_  
\_\_\_\_\_ (Name of Bank) of having our registered office at \_\_\_\_\_ [name of country] having our registered office at \_\_\_\_\_ (hereinafter called “the Bank”) are bound unto Secretary, Jaipur Development Authority. (Hereinafter called “the Employer”) in the sum of Rupees \_\_\_\_\_ [**Amount of Security in figures**] \_\_\_\_\_ (in words) only for which payment will and truly to be made to the said Employer, the Bank binds itself, its successors, and assigns by these presents. That on demand of JDA , this Bank Guarantee is encashable at following branch in Jaipur City.

1. Name of Bank:
2. Name of the branch with branch code:
3. Address:
4. E-Mail Id:
5. Telephone No.
6. Fax No.:

SEALED with the Common Seal of the said Bank this \_\_\_\_\_ day of \_\_\_\_\_ of 20\_\_\_\_.

THE CONDITIONS of this obligation are:

- (1) if the Bidder withdraws his Bid during the period of Bid validity specified in the Form of Bid;
- (2) if the Bidder refuses to accept the correction of errors in his bid;

- (3) If the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;
- (a) fails or refuses to execute the Form of Agreement in accordance with the Instructions to Bidders, or
  - (b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

We undertake to pay to the Employer up to the above amount upon receipt of his first written demand, without the Employer having to substantiate his demand, provided that in his demand the Employer will note that the amount claimed by him is due to him owing to the occurrence of one or more of the above conditions, specifying the occurred condition or conditions.



This Guarantee will remain in force up to and including the date 30 days after the date of expiration of the Bid Validity, as stated in the Instructions to Bidders, or any such extension thereto as may be agreed by the Bidder, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

The amount covered under the above Bank Guarantee shall be automatically be credited in the accounts of JDA in ICICI Bank, JDA Campus, Jaipur through **ISFC code No ICICI 006754. Bank Account No. 675401700518** on the date of expiry or its validity, unless the agencies get it re-validated well before its expiry date or produce NOC from JDA in written for its release.



Date \_\_\_\_\_ Signature of the Bank \_\_\_\_\_

Witness \_\_\_\_\_ Seal \_\_\_\_\_ [Signature,  
Name and Address]

[Note: To be furnished on appropriate non-judicial stamps.]

Tender Inviting Authority: Jaipur Development Authority, Jaipur						
Name of Work : Rate Contract for Addition/Alteration of Traffic Signalization work at various Crossing in Jaipur City.					 VALIDATE	
Contract No: NIB No- E.E. (Elect.-III)/4(i)/2016-17						
Bidder Name:				Less (-)		% 
SCHEDULE OF WORKS						
Sl. No.	Description of work	No. or Qty.	Unit	Estimated Rate		AMOUNT Rs. P
				Figure	Words	
1.00	SITC of WitraC 32Bit Microcontroller based Solar Power/ PWM Automatic Electronic controller, conformin to IEC-timer, GPSbased control board, blinker unit for night operation and slip lane, day time peak hours operation, the controller shall have 32 signal phase, signal switching and plan, 24 cycle switching/days, 20 selective days/annum, 4- 16 optically isolated solid state lamp driving outputs, 16 optically isolated vehicle detector, 20 X 4 LED backlit LCD and 5 X 4 keypad 8 Auxiliary I/O interface, USB CAN, R.S. 232 communication and 4 hurry call inter phase, manual override facility up gradable ehicle actuated system, also have method of traffic control with fixed time isolated intersection and cable less/cabled interlinking for synchronized operation, including additional features such as (a) facility to enter traffic volume, (b) Provision for 3 to 5 second Red/Green flash before starting of stage, (c) Red light violation data from all the approaches and (d) Using external ethernet adapter to USB for using 3G dongle outer for Networking and making connections. Technology developed by CDAC					
1.10	Master controller (Size L-607 X W-298 X D-176mm.)12 V DC ±10% 3.6 W	5.00	Each	108583.00	Rupees One Lakh Eight Thousand Five Hundred & Eighty Three Only	542915.00
1.20	Slave controller (L-400 X W - 298 X D-176 MM) 12 V DC ± 10% 3.0 W	20.00	Each	63236.00	Rupees Sixty Three Thousand Two Hundred & Thirty Six Only	1264720.00
2.00	S.I.T.C. of Programmable Two digit digital countdown timer with 5 mm dia.Red & Green colored LED of High intensity (visible clearly at day time) digit PCB size 300 mm round dia. CDAC, Shakti, Keltron	50.00	Each	8800.00	Rupees Eight Thousand Eight Hundred Only	440000.00
3.00	SITC of following colour retrofit LED matrices traffic light of modular size 300 mm dia, covered with front clear acrylic sheet and back with aluminum body , InP/InGaN based 5mm dia. Coloured LED's of ultra bright. Super intensity (Visible clearly at day time up to istance 300-600 meter, viewing angle of 30 degree). The unit is suitable for working on A.C. supply (160-240 V) and life cycle approx. 10 Years with power consupion below 12 Watts, suitable for fast switching, Make CDAC, Shakti, Keltron					
3.10	Static Red man & Walking Green man (Two in One)	50.00	Each	7700.00	Rupees Seven Thousand Seven Hundred Only	385000.00
3.20	Two in one (Red & Green for cycles)	50.00	Each	6600.00	Rupees Six Thousand Six Hundred Only	330000.00
4.00	Supply, Installation, Testing & Commissioning of 7.5M height galvanized polygonal signal pole with dia 350mm A/F, 4mm thickness with 6M cross arm with dia 90 mm A/F, thickness 4 mm fabricated from HT steel conforming to BS EN 10025, S-355 JO with 520x16mm base plate Make CDAC, Shakti, Keltron, Bajaj	6.00	Each	145000.00	Rupees One Lakh Forty Five Thousand Only	870000.00
5.00	P/Laying P.V.C/XLPE insulated & P.V.C sheathed cable of 1.1 KV grade with Copper conductor of IS: 1554 P-I/IS: 7098 P-I of Group 1 of approved make in ground as per IS: 1255 including excavation of 30cm x 75cm size trench, 25cm thick under layer of sand, lIInd class bricks covering, refilling earth, compaction of earth, making necessary connection, testing etc. as required of size.					
5.10	2.5sq mm. Armored 4 core	29360.00	Mtr.	162.40	Rupees One Hundred & Sixty Two and Paise Forty Only	4768064.00
6.00	SITC of microprocessor based logic type automatic electronic controller conforming to IS:7537 for traffic signals complete with electronic timer , control board, blinker unit for night operation and slip lane, day time peak hour operation, The controller shall have 12 Signal phases, 25 Signal plan, 24 cycle plan, 24 Signal split/ cycle, 4 Day plan, 32 Cycle switching/ day, 20 Selective Day plan/ annum, 16 Conflicting condition, 28 Signal Line, Solid-state relay switching, RS 422 Communication interphase, Manual override facility, up gradable vehicle actuated system, also have method of traffic control with fixed time isolated intersection and cable less/ cabled interlinking for synchronised operation. The controller unit shall be totally enclosed in 1.6 mm thick metal box including making connection of KELTRON / Shakti / BEL(versa TMS model) or approved make.	10.00	Each	76000.00	Rupees Seventy Six Thousand Only	760000.00
7.00	P & F 4.5 mm thick M.S. traffic post with outer dia. 114.3mm, medium class and confirming to IS:1239(P-I) 5Mtr. Long (0.8 Mtr. Below ground level) suitable for fiber cap and M.S. base plate 300 mm x 300 mm x 6 mm including excavation of pit and grouting with P.C.C. of ratio 1:3:6 from bottom of the pole and up to 30 cm. above the ground level and 40 cm. dia. Including painting with rubber paint below ground level and red oxide on exposed surface and finishing with traffic yellow enamel paint in two coats compete as required.	40.00	Each	3880.00	Rupees Three Thousand Eight Hundred & Eighty Only	155200.00


Signature of Tenderer with seal

Tender Inviting Authority: Jaipur Development Authority, Jaipur						
Name of Work : Rate Contract for Addition/Alteration of Traffic Signalization work at various Crossing in Jaipur City.					 VALIDATE	
Contract No: NIB No- E.E. (Elect.-III)/4(i)/2016-17						
Bidder Name:				Less (-)		% 
SCHEDULE OF WORKS						
Sl. No.	Description of work	No. or Qty.	Unit	Estimated Rate		AMOUNT Rs. P
				Figure	Words	
8.00	P&F M.S. Cantilever swaged pole suitable for mounting signal head assembly of overall height 9.0 Mtr. (1.5 meter. Below ground level) with M.S. based plate of size 400mm x 400mm x 7mm including excavation of pit and grouting with P.C.C. of Ratio 1:3:6 from the bottom of the pole and up to 50cm above the ground level of 40 cm dia. Including painting with rubber coat below ground level and red oxide on exposed surface and finishing with two coats of traffic yellow enamel paint complete in all respect as required. The pole shall confirm following specifications as per IS:(1239 P-I) Top, middle, bottom length 1.80 Mtr, 3.60 Mtr., 6.0 Mtr. Respectively, outer dia. 88.9 mm, 114.3 mm, 139.7 mm respectively, thickness 4.05 mm, 4.5mm respectively.	30.00	Each	10800.00	Rupees Ten Thousand Eight Hundred Only	324000.00
9.00	S.I.T.C. of programmable three digit digital countdown timer with 5mm dia. Red colored LEDs of high intensity (visible clearly at day time) of reputed make with digit size 150mm x 300mm approx. and quantity of LEDs be approx. 800 no.s including interconnection with traffic signal controller and housing the LED assembly in sheet metal box of size approx. 750mm x 550mm with detachable pole arms clamps etc. as required. Keltron/Shakti/ BEL.	40.00	Each	8000.00	Rupees Eight Thousand Only	320000.00
10.00	S.I.T.C. of following colour retrofit LED matrices traffic light of modular size 300 mm dia. Covered with front clear acrylic sheet and back with aluminum body, InP/InGaN based 5mm dia. Coloured LEDs of ultra bright. Super intensity (visible clearly at day time up to distance 300-600 meter, viewing angle of 30 degree). The unit shall be suitable for working on A.C. supply (160-240 V) and life cycle approx. 10 yrs with power consumption below 24 watts, suitable for fast switching, (makes –Binay Keltron, Shati Bel or approved make)					
10.10	Red/Amber Round (unit of 200-220 Nos LEDs)	260.00	Each	3040.00	Rupees Three Thousand & Forty Only	790400.00
10.20	Green Arrow (Unit of 120-130 Nos LEDs)	260.00	Each	4400.00	Rupees Four Thousand Four Hundred Only	1144000.00
10.30	Red/Green pedestrian(Unit of 75- 80Nos LEDs)	150.00	Each	1960.00	Rupees One Thousand Nine Hundred & Sixty Only	294000.00
10.40	Add extra for SITC of M.S. housing for LED matrices	670.00	Each	952.00	Rupees Nine Hundred & Fifty Two Only	637840.00
11.00	Shifting of cantilever traffic post at same site including repair and transportation (within municipal limit ) as required. Including excavation of pit and grouting with P.C.C. of ratio 1:3:6 from the bottom of pole (1.40 meter. Below ground level) and up to 50 cm above the ground level and 40 cm dia. including painting with rubber coat below ground level as required.	40.00	Each	920.00	Rupees Nine Hundred & Twenty Only	36800.00
12.00	Painting of existing traffic post /cantilever pole /signal head assembly/controller box including removing of old rusted surface paint and applying red oxide finishing two coats of enamel paint as required.					
12.10	Traffic post	450.00	Each	120.00	Rupees One Hundred & Twenty Only	54000.00
12.20	Cantilever pole	450.00	Each	360.00	Rupees Three Hundred & Sixty Only	162000.00
12.30	Controller box	80.00	Each	100.00	Rupees One Hundred Only	8000.00
12.40	Signal head assembly 300 mm dia.	2500.00	Each	40.00	Rupees Forty Only	100000.00
13.00	SITC of pelican controller for safety of pedestrians crossing the road at the push of button . Pedestrian stop vehicles flying on road and green period is 3 to 30 seconds. Pedestrian flashing green/ red pelican . ( Keltron, Shakti or approved make)	5.00	Each	16000.00	Rupees Sixteen Thousand Only	80000.00
14.00	SITC of Crystal control Solar Road warning Blinker system with solar panel module with 300mm LED Module of minimum 190 Nos., Blinker Units, Charging circuit, suitable SMF Rechargeable Battery (12 Volt), including wiring, connections etc. complete in all	20.00	Each	10000.00	Rupees Ten Thousand Only	200000.00
15.00	SITC of Programmable Three Digit Digital Countdown timer with 5 mm dia. Red colored LED of High intensity (visible clearly at day time) digit PCB size 302 mm x 215 mm approx and Quantity of LED be approx 256 Nos. including inter connection with traffic signal controller and housing the LED assembly in sheet metal box etc. Complete (SHAKTI/BEL/KELTRON Make).	20.00	Each	4480.00	Rupees Four Thousand Four Hundred & Eighty Only	89600.00

Signature of Tenderer with seal

Tender Inviting Authority: Jaipur Development Authority, Jaipur

Name of Work : Rate Contract for Addition/Alteration of Traffic Signalization work at various Crossing in Jaipur City.



Contract No: NIB No- E.E. (Elect.-III)/4(i)/2016-17

Bidder Name:		Less (-)		%
--------------	--	----------	--	---

## SCHEDULE OF WORKS

Sl. No.	Description of work	No. or Qty.	Unit	Estimated Rate		AMOUNT Rs. P
				Figure	Words	
16.00	SITC of Road separating indicator, Yellow LED flashing light + back lit white arrow. (SHAKTI / BEL/ KELTRON Make).					
16.10	200 mm.dia product size 320x202x1063mm	10.00	Each	8160.00	Rupees Eight Thousand One Hundred & Sixty Only	81600.00
16.20	300mm, dia product size 480x230x 1440mm	10.00	Each	11200.00	Rupees Eleven Thousand Two Hundred Only	112000.00
17.00	SITC of Solar panel Module 12 Volt 18 Watt, REIL, SHAKTI, BEL	150.00	Each	2800.00	Rupees Two Thousand Eight Hundred Only	420000.00
18.00	SITC Traffic am X-Stream Integrated I.P. Based Camera for vehicle presence detection & video use for traffic monitoring, use can configuration view and control and system both side and remotely having following key Functionalities: (1) All in one Sensor (Camera Detector), (2) MPEG-4 Image Compression (3) Real Time Verification & Monitoring (4) Up to 24 "Virtual" Detection Zones.					
18.10	Camera Only.	40.00	Each	91163.20	Rupees Ninety One Thousand One Hundred & Sixty Three and Paise Twenty Only	3646528.00
18.20	Module only	15.00	Each	49485.60	Rupees Forty Nine Thousand Four Hundred & Eighty Five and Paise Sixty Only	742284.00
19.00	STIC of SurveyorVFT (IP Dome) APTZ Camera with 360 degree rotation and digital zoom facility, which is also a transmitter. It can be connected straight to the net work, video transmission via IP Coaxial, Fibre Optic or twisted Pair (UTP) in ceiling or pendant configurations for indoor or outdoor installation with Ex view 23X or 35X high resolution color on day/night camera with Vandal proof and pressurized housings and privacy masking.	20.00	Each	168800.00	Rupees One Lakh Sixty Eight Thousand Eight Hundred Only	3376000.00
20.00	SITC of Cutting back up surface up to 2 Mtr. Depth by digging by Bogi including all layers of crust for laying pipe line etc. and making good to original condition (excluding cost of bitumen)	3500.00	Mtr.	288.00	Rupees Two Hundred & Eighty Eight Only	1008000.00
21.00	SITC of battery bank of min 150 AH capacity comprising SMF/VRLA batteries, MS / Teakwood battery stand, interconnect wiring etc as required complete in all respect of rating:					
21.10	24 V DC	20.00	Each	51300.00	Rupees Fifty One Thousand Three Hundred Only	1026000.00
22.00	P & F in position frame made out of M.S. angle (riveted or welded) finished with two coats of red oxide and enamel paint including cutting, welding, holes etc. of following sizes as required.					
22.10	40mm x 40mm x 5mm	400.00	Mtr.	167.20	Rupees One Hundred & Sixty Seven and Paise Twenty Only	66880.00
23.00	Supply and erection of M S swaged tubular pole conforming to IS: 2713-1980 (part I to II) with galvanised base plate in position including excavation of the pit and filling the same with C.C. of M-20 grade (1:1.5:3) from base plate to 50 cm above ground level, with the help of steel frame not less than 40 cm dia up to 114.3mm outer dia and 50 cm beyond 114.3mm outer dia around the pole. Duly finished with cement plaster, earthing terminals, cable entry, GI cable sleeve complete as required. The pole shall be fabricated by using ISI mark tube for structural purpose of following height & designation. ( See Table E - 09 for specs. )					
23.10	7.5 Mtr. ( 410 SP - 5 )	5.00	Each	5126.40	Rupees Five Thousand One Hundred & Twenty Six and Paise Forty Only	25632.00
23.20	8.5 Mtr. ( 410 SP - 17 )	5.00	Each	5702.40	Rupees Five Thousand Seven Hundred & Two and Paise Forty Only	28512.00
24.00	Supply, Drawing and Testing of outdoor singlemode [ 9 micron ] glass Fiber Optic cable as per latest amendments of TIA /EIA 568B.3, GR 409 CORE / UL listed NEC 770 Standards in existing MS/PVC Conduits/ slotted channels with ferruling at both ends for identification.					
24.10	12 Fiber	5200.00	Mtr.	144.00	Rupees One Hundred & Forty Four Only	748800.00

Signature of Tenderer with seal

Tender Inviting Authority: Jaipur Development Authority, Jaipur						
Name of Work : Rate Contract for Addition/Alteration of Traffic Signalization work at various Crossing in Jaipur City.						VALIDATE
Contract No: NIB No- E.E. (Elect.-III)/4(i)/2016-17						
Bidder Name:				Less (-)		%
SCHEDULE OF WORKS						
Sl. No.	Description of work	No. or Qty.	Unit	Estimated Rate		AMOUNT Rs. P
				Figure	Words	
25.00	Supply , Drawing and Testing of 4 pair, 24 AWG UTP Cat 6 Cable as per latest ammendments of TIA /EIA 568 B.2-1 Specifications in existing MS/PVC Conduits including making connections to Information outlets and Patch Panels with ferruling at both ends for identification with nessorry tools for punching, stripping, crimping and testing required.	3800.00	Mtr.	28.80	Rupees Twenty Eight and Paise Eighty Only	109440.00
26.00	P / L of Double wall corrugated HDPE pipe confirming to IS : 14930 P - 1 & 2 with HDPE Coupler at 1 mtr. Depth below the ground for laying cable including making the trench and back filling , compaction of earth as required of Gemini or IS:14930 marked make. Outer Dia. / Inner dia.					
26.10	90 / 76 mm	3500.00	Mtr.	120.00	Rupees One Hundred & Twenty Only	420000.00
27.00	S & Laying following size' B ' class G.I. Pipe confirming to IS : 1239 P - 1 ( 1990 ) with accessories for laying earth conductor/strip / cable in ground/surface/recess as required					
27.10	80 mm dia.	120.00	Mtr.	443.20	Rupees Four Hundred & Forty Three and Paise Twenty Only	53184.00
27.20	100 mm dia.	180.00	Mtr.	533.60	Rupees Five Hundred & Thirty Three and Paise Sixty Only	96048.00
Total Estimated Cost in Figures						25717447.00
Quoted Amount					25717447.00	25717447.00
Quoted Rate in Words		Rupees Two Crore Fifty Seven Lakh Seventeen Thousand Four Hundred & Forty Seven Only				

Signature of Tenderer with seal