



No. JDA/EE (PHE-II)/2020/D-12

Date: 8-1-20

**MINUTES OF PRE-BID MEETING HELD ON 03.01.2020 AT 4.00 PM AT "Manthan Hall", Third Floor, Main Building, Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, JDA Campus, Jaipur for the work of "Providing Laying and Jointing of sewer lines with construction of manholes in PRN (South) area Package-1 of Phase-1 under PHE-II Jurisdiction, JDA, Jaipur"**

An Open Tender Enquiry was floated on 09.12.2019 for the work of "Providing Laying and Jointing of sewer lines with construction of manholes in PRN (South) area Package-1 of Phase-1 under PHE-II Jurisdiction, JDA, Jaipur". The last date for submission of bid is kept as 17.01.2020. In continuation a pre bid meeting was held on 3.01.2020 at 4.00 PM for the said work at Manthan Hall.

At the onset of the meeting a brief presentation including walk-thorough of the project was given by JDA officials.

In the pre-bid meeting following prospective bidders were present: -

1. Mr. Anjan Kumar of M/s. Parul Construction Company
2. Mr. Surendera Khandlwal of M/s. SBPL Infra Project
3. Mr. Sunil Sharma of M/s. Bhoorathnam Construction Co. (P) Ltd. Secanderabad
4. Mr. Anurag Prasad of M/s. 4<sup>th</sup> Dimension Infratach Pvt. Ltd.
5. Mr. Vinod Goyal of M/s. Vinod Kumar Goyal
6. Mr. Satish Goyal of M/s. Divija Construction
7. Letter dated 03.01.2020 of M/s. Ganpati's Constructions presented

The prospective above listed bidders raised various queries and presented few suggestions for inclusion/deletion in the Tender Document of the said work and also sought some clarifications regarding Technical Criteria for eligibility of the said work.

The representative of M/s. Parul Construction Company and M/s. Ganpati's Constructions also submitted their queries regarding the said work tender



# JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

www.jda.urban.rajasthan.gov.in

document in writing vide their letter dated 03.01.2020 handed over personally during in the pre-bid meeting. These queries are appended below for reference:-

S. No.	Name of prospective bidders	Suggestion by prospective bidders	Decision taken in pre-bid meeting by JDA officials (Agreed/Not Agreed)
1	M/s. Parul Construction Company, vide letter dated 03.01.2020 handed over personally during in the pre-bid meeting	a. For the pre qualification criteria of item no. 3 Construction of Cast in situ RCC manhole of Internal dia 1.5 mtr. and above should also be considered.	Not Agreed
		b. Construction of Brick Masonry manhole 1000 mm to 1500 mm internal dia should be considered.	Not Agreed
		c. Sewer house connection of size 100 mm and above should be considered.	Agreed, sewer house connection of size 100 mm and above dia will be considered.
2	M/s. Ganpati's Constructions, vide letter dated 03.01.2020 handed over personally during in the pre-bid meeting	a. Pre qualification criteria for pipe, material of pipe is to be considered.	Not Agreed
		b. Pre qualification criteria for construction material i.e. RR/Precast / Cast in situ for manholes upto 1.5 mtr. dia mtr. will be consider.	Not Agreed

There being no more points the meeting was adjourned

(Mukesh Kumar Meena)  
Executive Engineer (PHE-II)  
Jaipur Development Authority,  
Jaipur